



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
NO OBJECTION CERTIFICATE**



Ack. No.:	122090002018	Issue Date :	04/11/2018	
NOC:	0005303/OCCU/Warangal - Urban/2018			
NOC TYPE:	OCCUPANCY*			
Valid Upto:	03-11-2023			
Applicant Details:	Anvish Rao-9849168398/thimmapur warangal			
Building for which NOC issued:	BIRLA OPEN MINDS SCHOOL. ,BIRLA OPEN MINDS SCHOOL. H.NO. 33-7-187 Thimmapur warangal,Thimmapur,Fort Warangal,Warangal - Urban			
Concessions in Setbacks Given in Lieu of Land Surrendered in Road Widening:	No			
Plot Area (Sq. Mtrs) :	16185.00	Height (Metres):	9.90	
Open Spaces (Metres):	North: 7.00	South: 6.00	East: (F) 10.00	West: 7.00
No. of Floors:0 Cellars, 0 Stilts, 1 Ground, 0 Mezzanines, 2 Floors, 0 Terrace	Occupancy Type:		EDUCATIONAL B-1 Schools up to senior secondary level	
Total Built-up Area (Sq.Mtrs):	7425.49	Staircases:	No. of Staircases Provided:	4
Fees Paid (Rs.):	216810		Aggregate Width Provided (Metres):	7.70

Minimum Fire Fighting Installations Provided as per Table 7, Part-IV of NBC, 2016:

Fire Extinguisher:	51	First Aid Hose Reel:	8	Wet Riser:	0
Down Comer:	0	Yard Hydrant:	0	Automatic Sprinkler System:	0
Manually Operated Electronic Fire Alarm Systems:	0	Terrace Tank (Litres):	20000		
Automatic Detection and Alarm System:	0	Underground Static Water Storage Tank (Litres):	25000		

Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm2 at Terrace Level	Type	Quantity	(Capacity in Litres/min)
	Electrical	0	0
	Diesel	0	0
	Jockey	0	0
Fire Pump at the Terrace Tank Level with Minimum Pressure of 2.0 kg/cm2	(Capacity in Litres/min)		
	450		

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"

For details and conditions of No Objection Certificate for Occupancy, refer overleaf.

Handwritten signature